

MEETING DATE: October 14, 2021

TIME: 6:00pm

If Applicable please fill in Executive Session START TIME: _____
state approx time:

END TIME: _____

Re-open to Public? If yes _____

SUBJECT of Executive Session: _____

BOARD OF HEALTH
NAME of BOARD/COMMITTEE

Town Clerk Office
Use Only

Butterick Municipal Building, One Park Street, Sterling, MA Basement meeting Room
LOCATION ROOM

Name: David Favreau

DESIGNATED AUTHORITY OF BOARD/COMMITTEE CALLING THE MEETING

AGENDA

6:00: Meeting to order. Roll Call

General Business Updates....including but not limited to the following:

1. Organization of the Board of Health
2. Approve any available minutes: September 9, 2021
3. Correspondence:
4. Health Agent Report:
5. Signatures Required: None
6. Other Items:

Discuss Coronavirus:

- (A) Town of Sterling Updates
- (B) DPH State Updates
- (C) Booster vaccinations

6:15: Appointments and Agenda Items:

7. 241 Redemption Rock Trail Variance Request (CONTINUED):

Sterling Subsurface Sewage disposal Regulations: Reg. IV. a., Leach beds to be 1000 square feet minimum, with 12" of stone beneath the pipes (456 sq. ft. provided with 6" stone beneath pipes).

Reg. IV. f., Leaching facilities 0-1,499 GPD shall be constructed with the following minimum 5 foot separation distance to estimated seasonal high groundwater (4 feet separating is proposed).

Local Upgrade Request: 310 CMR 15.405(1)(h): Approving Authority may reduce the required 5-foot offset from the E.S.H.W.T. to the bottom of the proposed S.A.S. (Provided-4')

8. 3 Sterling Avenue Variance Request:

Local Upgrade Request: 310 CMR 15.405(1)(h): Approving Authority may reduce the required 4-foot offset from the E.S.H.W.T. to the bottom of the proposed S.A.S. (Provided-3').

Sterling Subsurface Sewage disposal Regulations: Reg. IV. a., Leach beds to be 1000 square feet minimum, with 12" of stone beneath the pipes (1508 sq. ft. Presby sand bed provided with no stone beneath pipes).

Reg. IV. f., Leaching facilities 0-1,499 GPD shall be constructed with the following minimum 4 foot separation distance to estimated seasonal high groundwater (3 feet separating is proposed).

9. **110 Clinton Road Variance Request:**

Sterling Subsurface Sewage disposal Regulations: Reg. IV. f., Leaching facilities 0-1,499 GPD shall be constructed with the following minimum 4 foot separation distance to estimated seasonal high groundwater (3 feet separating is proposed).

Local Upgrade Request: 310 CMR 15.405(1)(h): Approving Authority may reduce the required 4-foot offset from the E.S.H.W.T. to the bottom of the proposed S.A.S. (Provided-3')

10. **12 Jewett Road review of reserve area design.**

Review of future agenda Items and meeting date.

To participate remotely;

Join Zoom Meeting

<https://zoom.us/j/2038723617?pwd=WWozdTFhQ0JDYzNMRFpEaUFpWjJvZz09>

Meeting ID: 203 872 3617

Password: 1ParkSt

Alternatively

To participate remotely;

Conference call option available

Dial in # 646-558-8656

Meeting ID: 203 872 3617

Password: 461540

Adjourned