

MEETING DATE: September 8, 2022

TIME: 6:00pm

If Applicable please fill in Executive Session START TIME: _____ END TIME: _____ Re-open to Public? If yes
state approx time:
SUBJECT of Executive Session: _____

BOARD OF HEALTH
NAME of BOARD/COMMITTEE

Town Clerk Office
Use Only

Butterick Municipal Building, One Park Street, Sterling, MA Basement Meeting Room
LOCATION ROOM

Name: David Favreau
DESIGNATED AUTHORITY OF BOARD/COMMITTEE CALLING THE MEETING

AGENDA

6:00: Meeting to order. Roll Call

General Business Updates....including but not limited to the following:

1. Approve any available minutes: August 11, 2022
2. Health Agent Report: Sterling Fair 9/9 through 9/11 inspections.
3. Signatures Required: None
4. DPH – Interagency Updates
5. Other Items:

6:15: Appointments and Agenda Items:

6. **176 Clinton Road Variance Request:**

Sterling Subsurface Sewage disposal Regulations: Reg. IV. a., Leach beds to be 1000 square feet minimum, with 12” of stone beneath the pipes (750 sq. ft. of stone and pipe bed system provided with 12” stone beneath pipes).
Reg. IV. f., Leaching facilities 0-1,499 GPD shall be constructed with the following minimum 4-foot separation distance to estimated seasonal high groundwater (3 feet separation is proposed).

Local Upgrade Request: 310cmr 15.405(1)(h): Reduction of the required 4-foot separation between the bottom of the leach area and the estimated seasonal high ground water table (3-foot separation provided between the bottom of the leach area and the estimated seasonal high ground water table).

7. **246 Worcester Road:**

Sterling Subsurface Sewage disposal Regulations: Reg. IV. a., Leach beds to be 1000 square feet minimum, with 12” of stone beneath the pipes (1088 sq. ft. of Presby type system provided with no stone beneath pipes).

Review of future agenda Items and meeting date.

Adjourn